



- This is not an installation drawing.
- The final coordination of services, specialist Sub-Contractors, and building structure is the responsibility of the building services Contractor.
- Do not scale from this drawing.
- This drawing shall be read in conjunction with the MEP Specification.
- The installation of services shall be in compliance with the workmanship clauses detailed in the Specification.

Notes

Legend

- EX1
Thorn Piazza II
15W, 1814 Lumens
3000K
3m Mounting Height
- EX2
Thorn Isaro Pro
19W, 2735 Lumens
3000K
5m Columns
- EX3
Thorn Candle Bollard
8W, 605 Lumens
3000K
1m High

Isoline Legend	
Illuminance (Lux)	
Color	Value
	0.5
	1
	2.5
	5

Safety, Health & Environmental Information

In addition to the hazards / risks normally associated with the types of work detailed on this drawing, note the following:

- Construction**
1. None identified at date of issue.
- Maintenance / Cleaning**
1. None identified at date of issue.
- Decommissioning / Demolition**
1. None identified at date of issue.

It is assumed that all works will be carried out by a competent contractor working, where appropriate, to an approved method statement

Issued for Planning - Updated	RS	April 24	P02
Issued for Planning	RS	April 24	P01
Details	Eng	Date	Rev

Revisions

Consulting Engineers
Faraday House, Terra Nova Way
Penarth Marina, Cardiff CF64 1SA
Tel. (029) 2035 2450
Fax. (029) 2035 2451
www.mccannp.com
office@mccannp.com
Job Title



Darran Road Extra Care Unit

Drawing Title
Lux Plot

Scale	A1	Date	Authorised	Checked	Engineer	Drawn
1:250		April 24	CT	AC	RS	RS
McCann Ref	Status	Information			Status Code	Revision
7321					S1	P02
Project	Origin	Volume	Level	Type	Discipline / Number	
7321	MCP	ZZ	ZZ	DR	E	9000